Data Collected By: **Kasey Ingram** **Building:** **2** **Floor:** **1** **Date Sampled:** **07/13/04**

PERIOD 1										**PERIOD II**								
Sample Site	Outside Building 1	Museum	Security Desk	In front Metal Detector	By Front Entrance	Front Desk	East side Of Museum	Elevator Lobby		Outside Building 1	Museum	Security Desk	In front Mental Detector	By Front Entrance	Front Desk	East side Of Museum	Elevator Lobby	
Time	08:20	08:24	08:28	08:30	08:33	08:35	08:38	08:41		04:01	04:03	04:05	04:07	04:08	04:11	04:13	04:16	
Temperature	78.0	77.7	75.1	74.9	74.4	74.8	75.2	75.1		81.1	75.9	76.5	73.9	76.5	78.1	74.7	79.3	
Relative Humidity	78.4	49.5	60.0	48.9	55.4	48.7	47.1	45.6		72.9	47.6	61.2	52.8	60.1	48.3	48.7	48.6	
Carbon Dioxide	428	434	443	455	416	416	430	434		347	556	558	546	528	574	551	637	
Carbon Monoxide	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Air Sample #	MEA-2-Out-04	MEA-2-1-01	MEA-2-1-02				MEA-2-1-03	MEA-2-1-04										
Results in CFU/m3	1402	318	271				106	506										
Notes																		

Data Collected By: **Kasey Ingram** **Building:** **2** **Floor:** **2** **Date Sampled:** **07/13/04**

PERIOD 1																		
Sample Site	Room 2103-2115	By Elevator	Hallway B Fountain	Cafeteria	Confer-Rence Room	Room 2390	Room 2378	Hallway A Entrance		Room 2103-2115	By Elevator	Hallway B Fountain	Cafeteria	Confe-Reence Room	Room 2390	Room 2378	Hallway A Entrance	
Time	08:20	08:24	08:28	08:30	08:33	08:35	08:38	08:41		03:34	03:36	03:38	03:40	03:42	03:44	03:46	03:49	
Temperature	77.7	79.0	78.1	78.3	76.1	76.5	76.3	77.4		76.3	77.5	77.5	77.4	75.2	75.4	74.3	75.6	
Relative Humidity	51.0	53.5	54.1	51.7	50.4	54.4	52.9	52.3		50.2	52.3	51.7	52.1	50.4	53.7	53.6	52.9	
Carbon Dioxide	437	435	435	428	467	461	472	525		610	617	552	572	554	564	564	587	
Carbon Monoxide	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Air Sample #	MEA-2-2-03		MEA-2-2-02	MEA-2-2-01				MEA-2-2-04										
Results in CFU/m3	612		294	71				71										